



WATER REQUIREMENT

WATER REQUIREMENT "A"
 FIELD ELEVATION
 -WITHIN 30m OF FIELD
 -DOWNSTREAM OF
 BACKFLOW
 IS 369 l/min @ 6.01 Bars

IRRIGATION LEGEND

- PRODUCT DESCRIPTION**
- HUNTER I25-04-SS-B-XXI125-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I25-04-SS-B-XXI125-06-SS-B-XX NOZZLE AS SHOWN
- NOZZLE PERFORMANCE:**
- #15 @ 5.5 Bars - 61.5 l/min 17.7m RADIUS
- ⊕ HUNTER ICV/IBV ELECTRIC CONTROL VALVE SIZE AS SHOWN
 - ⊕ HUNTER HQ44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
 - ⊕ HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
- WATER METER MINIMUM SIZE @ 369 l/min IS 63mm**
- Ⓜ BACKFLOW PREVENTER SIZED TO SYSTEM l/min
 - MAINLINE PIPE
 - LATERAL PIPE
 - ≡≡≡ SLEEVING
 - Ⓜ ISOLATION VALVE LINE SIZED
 - Ⓜ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 32mm SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
6. LATERAL DEPTH TO BE NO LESS THAN 410mm
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/QCV'S OUT OF HIGH TRAFFIC AREAS
9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
10. OCV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RIN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "F-S" FOR DIRTY WATER VALVE
16. ADD HUNTER "A-S" FOR PRESSURE REGULATED VALVE

VALVE ID GUIDE

A1	STATION NUMBER	273
A1	VALVE SIZE	1.5"
A1	PRECIPITATION RATE mm/hr	19

SYSTEM PERFORMANCE DATA

ZONE	SIZE	FLOW m ³ /hr	PR mm/hr	DU	SC (10% WINDOW)
A1	2"	14.8	22.9	.82	1.2
A2	2"	14.8	24.6	.82	1.2
A3	2"	18.5	30.8	.82	1.2
A4	2"	18.5	30.8	.82	1.2
A5	2"	14.8	24.6	.82	1.2
A6	2"	14.8	22.9	.82	1.2
A7	2"	14.8	24.6	.82	1.2
A8	2"	22.1	36.9	.82	1.2
A9	2"	14.8	24.6	.82	1.2
A10	2"	18.5	30.8	.82	1.2
A11	2"	14.8	24.6	.82	1.2
A12	2"	18.5	30.8	.82	1.2
A13	1.5"	11.1	18.5	.82	1.2
A14	2"	22.1	36.9	.82	1.2
A15	1.5"	11.1	18.5	.82	1.2

Hunter Industries offers this plan as a general guide for estimating purposes and does not warrant, expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.



AUSTRALIAN FOOTBALL FIELD
I-25 EIGHT ROW DESIGN
LOOPED MAINLINE

Hunter Industries
 1940 Diamond Street
 San Marcos, California 92078
 SpecPro Technical Assistance
 1-800-319-4796
 www.HunterIndustries.com

SHEET
1 OF 1