



WATER REQUIREMENT

WATER REQUIREMENT AT
-FIELD ELEVATION WITHIN 30m OF FIELD
-DOWNSTREAM OF BACKFLOW
IS 27.4 l/min @ 5.91 Bars

IRRIGATION LEGEND

- PRODUCT DESCRIPTION**
- HUNTER I-20-AD5-XX/1-20-6P-AD5-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
 - HUNTER I-25-04-SS-B-XX/1-25-06-SS-B-XX NOZZLE AS SHOWN
- IRREGULARITIES**
- ⊗ ISOLATION VALVE LINE SIZED
 - ⊗ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 32mm SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
6. LATERAL DEPTH TO BE NO LESS THAN 410mm
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/QCV'S OUT OF HIGH TRAFFIC AREAS
9. WIRE SPLICE CONNECTIONS TO BE WATERPROOF
10. QCV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

SPRINKLER PERFORMANCE DATA

ZONE	SIZE	FLOW (l/min)	PR (m/m)	DJ	SC (mm WINDROW)	
A1	1.5"	195	11.9	.86	1.2	
A2	1.5"	164	10.2	.80	1.3	
A3	1.5"	10.5	27.9	.80	1.3	
A4	2-1"	8.2	137	53.1	.80	1.3
A5	1.5"	12.4	206	27.9	.80	1.3
A6	1.5"	16.4	274	27.9	.80	1.3
A7	1.5"	12.4	206	24.3	.80	1.3
A8	1.5"	14.8	246	14.4	.86	1.2
A9	1.5"	11.2	186	14.4	.86	1.2
A10	1.5"	14.9	246	14.4	.86	1.2

VALVE ID GUIDE

AT	STATION NUMBER	VALVE SIZE	PRECIPITATION RATE (mm/hr)
223		1.5"	19.0
19.0			



SOFTBALL FIELD
I-25 FOUR ROW DESIGN
LOOPED MAINLINE

Hunter Industries
1940 Diamond Street
San Marcos, California 92078
SpecPro Technical Assistance
1-800-319-4796
www.HunterIndustries.com

SHEET
1 OF 1

Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity, expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.